

c. 98

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2022/ 683

Dated: 10/11/22

To,

The Principal,  
Delhi Heritage School,  
Main Kanjhawala Road, Sector-22,  
Rohini-110085.

**Sub:** Renewal of Fire Safety Certificate in r/o Delhi Heritage School, Main Kanjhawala Road, Sector-22, Rohini-110085.

Sir,

This is in reference to your letter No. nil dated 24.09.2022 received through outdoor diary no. 6143 dated 27.09.2022 on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 196 & 384 dated 28.04.2022 & 08.07.2022 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 28.04.2022 & 08.07.2022 for further consideration in this matter

Yours Faithfully

  
(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel:-01123414250

o/c  
Chy

1-67

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2022/ 384

Dated: 8/7/22

To,

The Principal,  
Delhi Heritage School,  
Main Kanjhawala Road, Sector-22,  
Rohini-110085.

**Sub:** Renewal of Fire Safety Certificate in r/o Delhi Heritage School, Main Kanjhawala Road, Sector-22, Rohini-110085.

Sir,

Kindly reference to online mail dated 15.05.2022, received in this department on the subject cited above. In this connection submitted the building was visited by officer on dated 27.05.2022 however, it has been observed that the shortcoming already issued by this department letter of even No. 196 dated 28.04.2022 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings already issued vide this department letter dated 28.04.2022 for further consideration in this matter.

Yours Faithfully

  
(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel:-01123414250

ac  
24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

Dated: 28/04/2022

No. F6/DFS/MS/WZ/School/2022/ 196

To,

The Principal,  
Delhi Heritage School,  
Main Kanjhawala Road, Sector-22,  
Rohini-110085.

**Sub:** Renewal of Fire Safety Certificate in r/o Delhi Heritage School, Main Kanjhawala Road, Sector-22, Rohini-110085.

Sir,

This is in reference to your letter No. nil dated 07.03.2022 received through outdoor diary no. 7109 dated 07.03.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **04.04.2022**, in presence of **Smt. Vibha Gupta (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (4) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire protection system found disconnected from water tanks in both the blocks.
2. Additional construction found carried out on terrace of third floor of B-block.
3. No ventilation found in staircase of B-Block.

As this is a case of addition/alteration, you are requested to submit sets of building plans on a scale of 1:100 including elevation for entire building through building sanctioning authority i.e MCD/DDA duly marked with fire & life safety provisions as stipulated in NBC for further consideration in this matter.

Yours faithfully

(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel:-01123414250

04  
04