

C. 50

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 688

Dated: 14/11/2022

To,

The Principal,  
Delhi International Public School,  
Sector-9, Rohini,  
Delhi-110085.

**Sub:** Issue of FSC in r/o Delhi International Public School, Sector-9, Rohini, Delhi-85.

Sir,

Kindly reference to online e-mail dated 02.10.2022 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **14.10.2022**, in presence of **Sh. Vipin Bhatia (Secretary Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace Fire pump with capacity 900LPM & 450 lpm provided but not functional.
2. Additional construction found to be carried out on terrace of third floor.
3. One more new block found in school.

As this is a case of addition/alteration, you are requested to submit sets of building plans on a scale of 1:100 including elevation for entire building through building sanctioning authority i.e MCD/DDA duly marked with fire & life safety provisions as stipulated in NBC.

Yours faithfully

  
(Atul Garg)  
DIRECTOR  
Ph; 011-23414000

on  
Date