

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 946

Dated:- 9.11.2022

To,

The Manager,
M/S **Golden Gate** Guest House,
3155-57, Sangtrashan, Pahar Ganj,
New Delhi.

Sub: Regarding renewal of FSC in r/o M/S Golden Gate Guest House, 3155-57, Sangtrashan, Pahar Ganj, New Delhi.

Sir,

This has reference to your online ID No. 2022101419043 dated 14/10/22, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 01.11.22 in presence of **Manager** and following shortcomings were observed:

1. Smoke management & CO detectors are not installed as per gazette notification 27.05.2019.
2. Hose reel found nonfunctional.
3. Pump not in auto mode provision.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,



(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.