

0/93



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

To No. F.6/DFS/MS/WZ/2022/ 942

Dated: 07/11/22

Sh. Amit Chadha  
Hotel Shubham Vilas,  
A-42, Vishal Enclave,  
Rajouri Garden, New Delhi-110027.

Sub.:- Regarding inspection report in r/o M/s. Hotel Shubham Vilas, located at A-42, Vishal Enclave, Rajouri Garden, New Delhi-110027.


Sir,

This is in reference to your online application received through MHA portal vide ID No 2022101118922 dated 11/10/2022 on the subject cited above. In this regard, it is to inform you that the aforesaid guest house was granted fire safety certificate vide this office letter No. F6/DFS/MS/GH/WZ/2022/449 dated 29/09/2022 the building was re-inspected by the officer concerned of this department on 19.10.2022 to check the provisioning of fire check doors as per letter No. F.5 (189)/AD/LB/2016/5514-31 dated 31/05/2022 of Directorate of Local Bodies, Urban Development Department.

During the course of the inspection, it was observed that the management has provided the fire check doors.

In view of above, this department has no objection to continue the occupancy subject to the condition that all the fire safety measures shall be kept in good working condition and means of escape arrangements shall always be kept free from any obstructions in the interest of occupant safety.

Yours faithfully

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to: -

1. The Joint Commissioner of Police (Lic), 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi. Email Id- [adclcp.lic-dl@nic.in](mailto:adclcp.lic-dl@nic.in)
2. The Dy. Health Officer, MCD, West Zone, Vishal Enclave, Rajouri Garden, New Delhi - 110027. Email Id- [dhowestzone@gmail.com](mailto:dhowestzone@gmail.com)

  
04/11/22