GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/ 686

Dated: 14/11/2022

067

To,

The Principal, Lancer's Convent Sr. Sec. School, Sector-14, Rohini, Delhi-85.

Sub:Issue of FSC in r/o Lancer's Convent Sr. Sec. School, Sector-14, Rohini, Delhi-85.

Sir,

Kindly reference to online e-mail dated 21.09.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **14.10.2022**, in presence of **Sh. Lalit Solanki** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

- 1. 6.0 mtr road all around the building is not provided.
- 2. Staircase ventilation not provided.
- 3. FCD is not provided in staircases.
- 4. Smoke management /ventilation is not provided on upper floors.
- 5. MOEFA is not provided.
- 6. PA system is not available in some location.
- 7. Exit signage's at some location is not provided.
- 8. Lift lobby and pressurization is not provided & Fire Man switch is not provided.
- 9. Fire control room is not provided.
- 10. Building plan not matching with approved building plans at basement and upper floors and 2nd floor library area.
- 11. Part of the building shown for demolition is not yet demolished.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under subrule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully DIRECTOR Ph; 011-23414000

