

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/NDZ/2022/ 687

Dated: 14/ 11 /2022

To

The Principal,
Rabea Girls Public School,
Gali Qasimjan, Ballimaran, Delhi- 110006.

Sub: Issuance of Fire Safety Certificate to **Rabea Girls Public School, Gali Qasimjan, Ballimaran, Delhi- 110006.**

Sir,

This has reference to your letter no.nil dated 20.10.2022 on the subject cited above. In this regard, it is to inform you that as per the guidelines issued by Director Education GNCTD vide their letter no. F1.6/1:state/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 in exercising the powers conferred under section 3 of Delhi School Education Act 1973 & Rule 43 of Delhi School Education Rules, 1973 for implementation of fire & life safety measures in the existing school building from fire life safety point of view.

In the aforesaid guidelines one point is related to access for the school building.

However, if the school building is not accessible to fire engines, Fire Safety Certificate is not considered by this department.

Hence in the case of Rabea Girls Public School, the Principal have been informed by this department vide our letters dated 08.03.2013, 14.08.2017, 11.09.2017, 23.10.2017, 21.03.2018, 24.04.2018, 16.05.2018, 18.07.2018, 19.12.2019, 07.07.2021, 20.06.2022 & 06.10.2022 regarding the shortcoming.

Yours faithfully,



(S. K. Dua)

Dy. Chief Fire officer
Delhi Fire Service
Tel: 011 23412222

ole
10/11

Copy to:-

The Director of Education, Old Secretariat, Delhi- 110054.