

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/NDZ/2022/ 945

Dated: 9 .11.2022

To

The Manger,  
Ricky Dx. Guest House,  
1242, Bazar Sangatrashan,  
Pahar Ganj, New Delhi.

**Sub:** Application for issuance of fire safety certificate in respect of **M/s Ricky Dx. Guest House** located at 1242, Bazar Sangatrashan, Pahar Ganj, New Delhi.

Sir,

This has reference to your online id no. **2022101519101** dated **15.10.2022**, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on dated **01.11.2022** in presence of **Manager** and observed that shortcomings issued earlier vide letter no. **F6/DFS/MS/NDZ/2022/560** dated **11/07/2022**(copy enclosed), have not been complied so far.

In view of above, FSC can't be issued till the compliance of all the shortcomings issued vide aforesaid letter.

Encl: As above.

Yours faithfully,

  
(S.K.Dua)

Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to :**

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

C-110

No.F6/DFS/MS/NDZ/2022/560

Dated:-11.7.2022

To

The Manager  
M /S **Ricky Dx. Guest House**,  
1242, Bazar Sangatrashan, Pahar Ganj,  
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S **Ricky Dx. Guest House**, 1242, Bazar Sangatrashan, Pahar Ganj, New Delhi.

Sir,

This has reference to online ID No. Online id no.2022042308071 dated 23.04.2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 01/07/2022 in the presence of **Mr. Rajesh Kapoor** and following shortcomings were observed:-

1. Smoke management system are not provided as per gazette notification dated 27.05.2019.
2. CO Detector, are not provided as per gazette notification dated 27.05.2019.
3. PA System found nonfunctional.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully

  
(S.K. Dua)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi