



219

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 691

Dated: 14/11/22

To,

The Principal,
Swami Ramtirth Public School,
C-9, Vijay Vihar,
Phase-1, Rithala,
Delhi-110085.

Sub: Issue of FSC in r/o Swami Ramtirth Public School, C-9, Vijay Vihar, Phase-1, Rithala, Delhi-85.

Sir,

This is in reference to your letter No. nil dated nil received through outdoor diary no. 6634 dated 11.10.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **28.10.2022**, in presence of **Mis. Asha Singh (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 6000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs.
2. Additional one more new block found in school.

As this is a case of addition/alteration, you are requested to submit sets of building plans on a scale of 1:100 including elevation for entire building through building sanctioning authority i.e MCD/DDA duly marked with fire & life safety provisions as stipulated in NBC.

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

DL
DL