

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/CGHS/2022/ 2852

Dated: 16/11/2022

To,

The President
Vasundhra CGHS Ltd.
Plot No-01 B, Sector-22 Dwarka,
New Delhi- 110077

Subject: Renewal of Fire Safety Certificate in r/o Vasundhra CGHS Ltd. Located at Plot No-01 B, Sector-22 Dwarka New Delhi- 110077.

Sir,

This is in reference to your Email, dated-08/10/2022 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 01/11/2022 in presence of Sh. Naveen (Society Employee).

During course of inspection the following shortcomings were observed.

1. Hoses & Branches found missing from hose box at some places.
2. Terrace pumps found non functional in auto mode.
3. Exit signage found removed at some places.
4. Communication system in the lift car found nonfunctional.

You are requested to comply the abovementioned shortcomings under intimation with this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to; - The Joint Director, DDA, Vikas Sadan, INA, New Delhi.