



No.F6/DFS/MS/Hospital/SZ/2022/ 2831

Dated: 15/11/2022

To

The Medical Superintendent,  
Ministry of Health & Family Welfare,  
Vardhman Mahavir Medical College & Safdarjung Hospital,  
New Delhi-29.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **M/s Boys Hostel Building, Safdarjung Hospital Complex, Ring Road, New Delhi-29.**

Sir,

With reference to your letter dated 20.09.2022 on the subject cited above, it is informed that the hostel building was inspected by Assistant Divisional Officer (M. Road) from this department on 28.09.2022 in the presence of Mr. Vivek Gupta Junior (JE) and it was observed that the building is comprised of Ground + 7 upper floors. During the inspection following shortcomings were observed:-

1. Main exit from the kitchen shall be provided with Fire Check Door (FCD) and an independent alternate exit of 1.50 meter shall be provided from the kitchen at ground floor.
2. Fire Check Door (FCD) provided in lift and staircase lobby were found non functional.
3. Fire hydrant system found removed at terrace.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Executive Engineer (E), CPWD, Safdarjung Hospital Electrical Division, New Delhi-29.