

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/CGHS/2022/ 2925

Dated: 22/11/2022

To,
The President <bgcggs@yahoo.com>
Brindavan Garden CGHS Ltd.
Plot No-10, Sector-12, Dwarka,
New Delhi- 110075

Subject: Renewal of Fire Safety Certificate in r/o Brindavan Garden CGHS Ltd. Located at Plot No-10, Sector-12, Dwarka New Delhi- 110075.

Sir,
This is in reference to your Email, dated-12/10/2022 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 04/11/2022 in the presence of Sh. Akash (Manager).

During course of inspection the following shortcomings were observed.

1. Six meter wide internal road found partially blocked / encroached.
2. Fire Check Door found removed in basement.
3. Smoke managements System Found Removed at some areas.
4. MOEFA found nonfunctional.
5. PA system found nonfunctional.
6. Lift Lobby found removed in basement.
7. Sprinkler system must be extended to left out area.
8. The pumps found nonfunctional in auto mode.
9. Exit signage found removed at some places.

You are requested to comply the abovementioned shortcomings under intimation with this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(A. Garg)
Director
Delhi Fire Service

Copy to: - The Joint Director, DDA, Vikas Sadan, INA, New Delhi.