

To

Ms. Sonal Jain,
Adishwar Apartment,
34, Firozshah Road, New Delhi.

Sub: Regarding renewal of FSC in r/ ADISHWAR APARTMENT, 34 Firozshah Road, New Delhi -01.

Sir,

This has reference to your e-mail < 34fzhrd@gmail.com > dated 31.10.2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by officers concerned of this department on dated 09.11.2022 in the presence of Estate Officer & General Secretary and the following shortcomings were observed:-

1. Fire Check doors found broken and at some places fire check door glass has been replaced with normal glass, required to be replaced with fire rated glass.
2. Terrace pump on front side block not provided.
3. Lift siganges "not to use lift in case of fire" is not installed.

In view of above, Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to rectify above shortcomings for further consideration in the matter. .

Yours faithfully


(Atul Garg)
DIRECTOR
011-23410000

Copy To

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Chief Engineer, NDMC, Palika Kendra, New Delhi.