

C15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZI/2022/EH/669

Dated:-22.11.2022

To

The Manager,
M/S House of Commons (A Unit of Saras Hospitality Service),
M-39, Second Floor, Connaught Circus,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/s House of Commons (A Unit of Saras Hospitality Service) at M-39, second floor, Outer Circle Connaught Place, New Delhi.

Sir,

This has reference to online ID No. 2022092418155 dated 24.09.2022 on the subject cited above, it is to inform you that the site was inspected by the officers concerned of this department on 07/11/2022 in the presence of Mr. Azaz and the following shortcomings were observed:-

1. One staircase of 1.40 meter is provided against the requirements of two staircase of 1.5 meter each.
2. 01 Exit door of 1.4 meter is provided against the requirement of two of 1.5 meter each.
3. First aid hose reel found non functional.
4. Hydrant system is not provided.
5. MOEFA is not provided.
6. Overhead fire water storage tank of capacity 20,000 Ltr is not provided.
7. Information mentioned in application form such as no. of specific floor, width of staircase, width of door, height of building, etc. is not filled properly.
8. Further, the building plan as uploaded does not have signature of architect & owner himself. The section /elevation of building is also required to ascertain the height of building & fire safety arrangements such as underground tank and pumping arrangements, detectors, etc.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

The Joint Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.