

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2022/SZ/ 673

Dated 22/ 11 /2022

To

The Dy. Health Officer, SDMC
Public Health Officer,
Aurobindo Marg, South Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Karim Restaurant, at Shop No 12 & 14 Khasra No 253, Village, Sultanpur, MG Road, New Delhi-110030


Sir,

This has reference to your MHA Portal 2022092017932 dated 25/10/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 13.11.2022 in the presence of Mr. Aamir Siddiqui (Manager) to verify the fire safety measures installed in the building and observed that restaurant running at Ground Floor only. During inspection, following points were observed:

- 1 There are two exits having width of 02 mtr & 1.52 mtr but the second exit found closed.
- 2 First aid hose reel hose provided but not functional.
- 3 Terrace levels pump capacity 450 LPM provided but not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter.