

C13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2022/School/717

Dated: 25/11/2022

To,

The Principal  
M.R. Vivekananda Model School,  
Sector - 13, Dwarka, New Delhi - 110078.

**Subject: Renewal of Fire Safety Certificate in r/o M.R. Vivekananda Model School Located at Sector - 13, Dwarka, New Delhi - 110078.**

Sir,

Please refer to your letter No. DW/44/5475, dated 18/10/2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 11-11-2022 in presence of M/s Alka Sinha (Principal) for fire safety point of view.

During the course of inspection the following shortcomings were noticed.

1. Iron Staircases are found blocked at all the floors and both the iron staircases of 1.25 m wide are too weak and a staircases stability certificate is required.
2. One staircase in basement found blocked.
3. Exhaust fan in basement found removed/ inadequate.
4. Hose Reel Hose & hydrant found nonfunctional.
5. Automatic Sprinkler System in basement found nonfunctional.
6. Terrace pump found removed.
7. Exit Signage's found removed at some places.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Sunil Chaudhary)  
Dy. Chief Fire officer  
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi - 110054.

150%  
22/11/22