



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75-49  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2022/ 719

Dated: 25/11/2022

To

The Principal,  
South Delhi Public School,  
D- Block, Defence Colony, New Delhi-24.

**Sub:-** Regarding renewal of Fire Safety Certificate in respect of **South Delhi Public School located at D- Block, Defence Colony, New Delhi-24.**

Sir,

This has reference to outdoor diary no. 5776 dated 16.09.2022 on the subject cited above. it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 14.11.2022 in the presence of Mr. B.S. Rana (Admin Officer) and it was observed that the building is comprised of ground + 2 upper floors. During the inspection following shortcomings were observed:-

1. An additional staircase is required of width 1.50 mtrs.
2. First aid hose reels found non function.
3. Fire pump found non function.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

9/11/2022

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST, South Block-C, Defence Colony, New Delhi-24.