

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/2022/SZ/ 2990

Dated: 29/11/2022

To,

Sh. Mukesh Kumar Tyagi,
Second in Command (Engr.) SHQ-Delhi,
ITBP Campus at Chhawla, New Delhi.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/S
Barrack ITBP Campus at Chhawla, New Delhi.

Sir,

Please refer to your letter No. ITBP/SHQ(Delhi)/Engr.Br./Chhawla Campus
Corr.File/07/2022-2572 Dated- 12/10/2022 on the subject cited above. In this connection this is
to inform you that officer concerned of this department inspected the building to verify the fire
safety arrangements in accordance with the rules. At the time of inspection Sh. Mukesh Kumar
Tyagi was present and it was observed that the building is comprised of ground plus five upper
floors and have following shortcomings:-

1. Pressurization/smoke management system provided but not functional.
2. First aid hose reel provided but not functional.
3. Manual Operated Electric Fire Alarm provided but not functional.
4. Public addressing system provided but not functional.
5. Down comer system provided but not functional.
6. Fire pump provided but not functional.
7. Exit signage's are provided but not sufficient.

In view of above shortcomings, the application for issuance Fire Safety Certificate is
rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements
shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory
Authority may be take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service