



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

C-49

No. F6/DFS/MS/WZ/2022/School/704

Dated: 22/11/2022

To,

The Principal,
Bal Bharati Public School,
Parwana Road, Pitampura,
Delhi.

Subj.:- Regarding renewal of Fire Safety Certificate in r/o Bal Bharati Public School, Unit-II (Primary Wing), Located at Parwana Road, Pitampura, Delhi-110034.


Sir,

Please refer to your email dated 02.06.2022 on the subject cited above. In this connection, it is to inform you that the said building have been inspected by the officers concerned of this department on 20.09.2022 in the presence of Sh. Pranab Bhattacharya (Caretaker). The School building (Primary Wing) comprised of Basement + Ground + 03 Upper Floors. The fire Safety arrangements such as fire extinguishers, first aid hose reel, exit signages & Overhead water storage tank etc found provided. However, the following points have been noticed as shortcomings:-

1. Basement floor in block of Unit- II (Primary Wing) in which FSC was issued are using as music, dance & other activities purposes which are not allowed as per BBL.

In view of the above shortcomings, Fire safety Certificate cannot be renewal at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,


(Dharampaul Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to :-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Dy. Commissioner (Bldg.), MCD office, P-496-276, Rohini institutional area, Sector 5, Rohini, Delhi.