



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2022/ 711

Dated: 22/11/2022

To

The Principal,
M/s EDMC Primary School, Hasanpur Village,
Delhi-110092.

Sub:- Inspection Report in r/o M/s EDMC Primary School, Hasanpur Village Delhi-110092.

Sir,

With reference to your Letter No. Nil Dated 12/10/2022 on the subject noted above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view on dated 15/11/2022 in the presence of Smt. Meenakshi Gupta (Principal). During the course of inspection Following shortcomings was observed during the time of inspection:-

1. A Fire Pump of 450 LPM capacity having head of 40 m provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be the risk and liability of the owner / occupier.

Yours faithfully


22/11/22

(S.K. DUA)

DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education (D.M.C.), Udyog Sadan, Plot No. 419, FIE, Patparganj,
Delhi-110092.