

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/NDZ/2022/ 2963

Dated:- 24.11.2022

To

The Deputy Director, Admin.,
Central Drugs Standard Control Organization (HQ),
Directorate General Health Services,
Ministry of Health and Family Welfare,
FDA Bhawan, Kotla Road, New Delhi.

Sub: Request for grant of Fire NOC in r/o Food Drugs Administrative Bhawan on Kotla Road, New Delhi (Near Mata Sundari College).

Sir,

This has reference to your letter no.F.NO.D.21013/125/2009-DC dated 01.11.2022, on the subject cited above. In this regard, it is to inform you that the site was inspected by officers concerned of this department on dated 16.11.2022 in the presence of Sh. Ankeshwara Misra and observed that the following shortcomings were still not complied:

1. Pumps are not on auto mode provision.
2. Further, 5th floor is temporary constructed, required to be removed or submit the sanctioned plans/regularized plan of the same.

In view of above shortcomings, request for renewal of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully


(Atul Garg)
DIRECTOR
011-23410000

Copy to:

- 1) The Commissioner,
MCD, Civic Centre, Minto Road,
New Delhi.