



C27  
75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2022/NDZ/ 715

Dated 23/11/2022

To,

The Principal,  
Govt. Boys Sr. Sec. School No.-1,  
Mansarovar Park, Shahdara,  
Delhi-110032

Sub:- Regarding Issuance Fire Safety Certificate in r/o Govt. Boys Sr. Sec. School No.-1, Mansarovar Park, Shahdara, Delhi-110032.


Sir,

This is in reference to your letter No. GBSSS/No.1/MSP/2022/767 dated- 10/10/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view on dated 09/11/2022 in presence of Mr Mukesh Babu, H.O.S. The building comprised of ground plus three upper floors. Following shortcomings were observed during the time of inspection.

1. First-Aid hose reels provided but not functional.
2. Terrace pump having 450 LPM output at 40 meter head provided but not functional.
3. Overhead water storage tank capacity 4,000 liters is provided against requirement of 10,000 liters.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

  
22/11/22

(S.K. DUA)

o/c  
DY. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education,  
B- Block Yamuna Vihar,  
Delhi-110053