



C-19

75
Azadi Ka
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/Instt./2022/NDZ/ *College/64*

Dated: *21/11/2022*

To,

Gp Capt. Sonpal Singh (Retd.)
(Secretary General)
Institution of Electronics & Telecommunication Engineers (IETE)
02, Institutional Area, Lodhi Road, New Delhi-110003

Subject: -Regarding issuance of Fire Safety Certificate in r/o Institution of Electronics & Telecommunication Engineers (IETE) located at Plot no. 30X, FC-18, Karkardooma Institutional Area, Delhi-110092.

Sir,

This is in reference to your letter No. IETE/ADMN/22 dated 20/09/2022 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department have carried out the inspection of the above mentioned Institute from fire safety point of view in presence of Mr. Arvind Kumar Pathak, Chief Librarian of the Institute. During the course of inspection, the following points / shortcomings were noticed in the building which is comprised of basement, ground plus three upper floors.

1. Smoke Management System not provided in the basement.
2. First-Aid Hose reels provided but not functional.
3. Fire pump having 450 lpm output of 60 meter head at terrace not functional.
4. Pressurization of lift shaft & lift lobby not provided.
5. Special Fire Protection System of Special risks panel not provided as per guideline letter no. F.6/DFS/MS/BP/2011/2217 dated 09/09/2011.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

Arvind
18/11/22
(S.K. DUA)

o/c
e. **DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE**