



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी का  
अमृत महोत्सव

No. F6 /DFS/MS/GH/SZ/2022 / 953

Dated: 15/11/2022

To

The Joint Commissioner of Police,  
Office of Joint commissioner of Police: Licensing,  
1st Floor, P S Defence Colony, New Delhi.

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Interior Crafts Guest House  
Located at A-36, Abul Fazal Enclave, Part -1, Jamia Nagar, Okhla , New Delhi.**

Sir,

With reference to online application no. 2022083016848 dated 30.08.2022 on the subject cited above, it is informed that the said building was visited by Assistant Divisional Officer (M. Road) from this department on 07.11.2022 in the presence of the Manager and it was observed that the shortcomings issued to the guest house vide letter no. F6/DFS/MS/GH/SZ/2022/819 dated 27.09.2022 has not been rectified completely till date (Photocopy enclosed). Hence FSC to the guest house cannot be considered at this stage.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang),

Director

Delhi Fire Service

9/11/22

**Copy to:-**

The Licensee, M/s Interior Crafts Guest House Located at A-36, Abul Fazal Enclave, Part -1, Jamia Nagar, Okhla , New Delhi.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी का  
अमृत महोत्सव

No. F6 /DFS/MS/GH/SZ/2022 / 819

Dated: 27/09/2022

To

The Joint Commissioner of Police,  
Office of Joint commissioner of Police: Licensing,  
1st Floor, P S Defence Colony, New Delhi.

**Sub:** - Regarding grant of Fire Safety Certificate in r/o **M/s Interior Crafts Guest House Located at A-36, Abul Fazal Enclave, Part -1, Jamia Nagar, Okhla , New Delhi.**

Sir,

With reference to the online application I.D. no. 2022083016848 dated 30.08.2022 on the subject cited above, it is informed that the said guest house was inspected by Assistant Divisional Officer (M. Road) from this department on 08.09.2022 in the presence of Mr. Ajay, manager and it was observed that the building is comprised of Basement + Ground + 04 upper floors. During the inspection the following shortcomings were observed:

1. 2 nos. of staircases having width not less than 1.5 mtrs. each should be provided.
2. Fire Check Door not provided in the basement staircase.
3. No ventilation in common corridor.
4. First aid hose reel found not provided.
5. Fire pump having capacity 450 LPM & 40 mtrs head found not provided.
6. Overhead tank capacity 5,000 liters for firefighting found not provided.
7. Exit signages found not provided.
8. Guest shall comply with the requirement of clause 7.31, UBBL 2016 latest by 30.09.2022.
9. Operation of the guest house above 3<sup>rd</sup> floor is not permitted as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

27/09/22

**Copy to:-**

The Licensee, M/s Interior Crafts Guest House Located at A-36, Abul Fazal Enclave, Part -1, Jamia Nagar, Okhla , New Delhi.