

e-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**

No: F.6/DFS/MS/School/2022/SZ/ 714

Dated: 23/11/2022

To,

The Principal,
New Sainik Public School,
F-3, Nand Ram Park, Mahavir Enclave Part-III,
New Delhi-110059.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. New Sainik Public School F-3, Nand Ram Park, Mahavir Enclave Part-III, New Delhi-110059.

Sir,

This has reference to your Letter No. 22/N.PS/Fire HQ dated 27/10/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 04/11/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Rajesh Singh (Manager) was present and it was observed that the school building is comprised of ground plus three upper floors but school running at ground plus two upper floors and have following shortcomings.

1. Both staircases shall be provided 1.5 m wide.
2. First aid hose reel not provided.
3. Fire Pump having 450 lpm not provided at terrace.
4. Over head water storage tank 10,000 liters not provided.
5. Exits signage's are not provided.

In view of above, issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Arul Garg)

Director

Delhi Fire Service

Copy to:-

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat