



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2022/ 697

Dated: 18 /11/2022

To

The Principal,  
Sarvodaya Kanya Vidyalaya (Janki Devi),  
Mayur Vihar, Pockit-II, Phase-I, Delhi-91.

**Sub: Regarding Renewal of FSC in r/o Sarvodaya Kanya Vidyalaya (Janki Devi), Mayur Vihar, Pockit-II, Phase-I, Delhi-91. School Id No. 1002034.**

Sir,

This has reference to your letter no. SKV(JD)/PKTII/MV/2022/788 dated 19/10/2022 on the subject cited above. In this regard, it is to inform you that reply has already been sent by this department vide letter no. F6/DFS/MS/School/NDZ/2020/624 dated 10/09/2020 & F6/DFS/MS/School/2021/489 dated 13/09/2021 (photocopy enclosed) have not been rectified so far. Keeping in view of above shortcomings, FSC can not be considered at this stage.

You are requested to submit the point wise compliance to this department for further necessary action in this regard.

Yours faithfully

Encl:- as above

(S.K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

The Director (Education),  
Govt. of NCT, Old Sectt.  
Delhi - 54.

C-3!

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2020/ 624

Dated: 10/09/2020

To,

The Principal  
Sarvodaya Kanya Vidyalaya,(Janki Devi)  
Mayur Vihar, Pocket-II,Phase-I, Delhi-91.

**Sub:** -Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o  
Sarvodaya Kanya Vidyalaya,(Janki Devi) Mayur Vihar, Pocket-II,Phase-I, Delhi-91.

Madam,

Please refer to your letter Nil Dated 06/08/2020 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the NBC Part-IV. At the time of inspection Mrs. Seema Singh Rathi (Principal) was present and it was observed that the school building is comprised of two blocks ground plus one & two blocks ground plus three upper floors and have following shortcomings:-

1. An alternate staircase of 1.5 m shall be required in new building block or to be connected through ramp as constructed for first floor.
2. Hose reel provided but not functional.
3. Fire pumps provided but not functional.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully



(Sunil Chawdhary)  
Dy. Chief Fire Officer

/cy.

Copy to:-

The Joint Director of Education (Land & Estate)  
Directorate of Education, Lucknow Road, Delhi-110054.