

C-21



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 706

Dated: 22/11/2022

To,

The Principal,  
Surya Public School,  
H No.12-A, 1<sup>st</sup> floor, Shiv Mandir Mohalla,  
Village Badli,  
Delhi-110042.

**Sub:** Issue of FSC in r/o Surya Public School, H No.12-A, 1<sup>st</sup> floor, Shiv Mandir Mohalla Village Badli, Delhi-110042.

Sir,

This is in reference to your letter No. nil dated 17.09.2022 received through outdoor diary no. 6232 dated 29.09.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **02.11.2022**, in presence of **Sh. Arun Kumar Mishra (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Alternate staircase of 1.50 mtr is found removed.
2. Required exit signage not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

**(Dhrampal Bhardwaj)**  
**Dy.Chief Fire Officer**  
**Tel;-01123414250**

Q-  
AM