

66

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F-6/DFS/MS/School/2022/ 699

Dated 18/11/2022

To

The Manager
Upkar Public School
Khasra No. 15/9, 15/10, D-Block,
Harit Vihar, Burari, Delhi-110084.

Sub: - Regarding issuance of fire safety certificate in r/o Upkar Public School located at Khasra No. 15/9, 15/10, D-Block, Harit Vihar, Burari, Delhi-110084.


Sir,

This has reference to your letter no. Nil and received in this department vide outdoor dairy no. 6949 dated 19.10.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 04.11.2022 to verify the fire safety arrangements provided therein as per the NBC Part-IV. At the time of inspection Sh. Vinod Kumar (Care Taker) was also present at site and said building was comprised of ground & two upper floors only. Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

1. The width of entrance gate is provided 04m & 2.50m against the requirement of 4.50m for movement of fire engine in case of emergency.
2. There is only one staircase provided width of 1.20m against the requirements of 1.50m each.
3. All class room doors size are 80cm provided against the requirements of 1.20m.
4. Only 01 nos. of fire extinguisher provided at site against the required of 12 nos.
5. Hose reel hose provided but found not functional at the time of inspection.
6. MOEFA system is not provided in the school building.
7. Terrace level fire fighting pump capacity of 450lpm provided but found not functional.
8. Overhead fire water tank capacity of 3,000ltr provided against the requirement of 10,000ltr.
9. Exit & floors signage's not provided at strategic location in the school building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully



(Atul Garg)
Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi 110054.