

E-4

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6 /DFS/MS/2022/ GH/NW2/983

Dated 28/11/2022

To,

The Secretary
Harijan Sevak Sangh Boys & Girls Hostel
Gandhi Ashram, Kingsway Camp, Delhi-110084.

Sub: - Regarding issuance of fire safety certificate in r/o Harijan Sevak Sangh Boys & Girls Hostel at Gandhi Ashram, Kingsway Camp, Delhi-110009.

Sir,

This has reference to your letter no. HSS/Fire Safety/2022-23/91 Dated: 19.09.2022 and received in this department vide outdoor dairy no. 5943 dated 21.09.2022 on the subject cite above, it is to inform that the said building was visit by ADO (R/N) on 28.10.2022 in presence of Sh. Sanjay Rai (Secretary) and it was observed that the Harijan Sevak Sangh Boys & Girls Hostel is comprised of ground & first floor only.

However, the residential building having height less than 15m or ground + 04 upper floor including mezzanine floor does not fall in the purview of Delhi Fire Service Act 2007 and Rules 2010. Hence Fire Safety Certificate from this department is not required.

However, Management of the Harijan Sevak Sangh Boys & Girls Hostel is requested to maintain the fire protection measures as per NBC Part IV. 2016 (table 7) in the large interest of public safety.

Yours faithfully,


(Anil Gang)
Director

Ph: 011-23414000

o/e Gp

Copy to:-

1. The Executive Engineer, NDMC, Building department, 8th floor, Civic Centre, Minto Road, New Delhi-01.