

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/Mixed/2022/SZ/ 3071  
To

Dated: 07/12/2022

M/s Land Mark Building Pvt Ltd  
LSC, Munirka, OLOF Palme Marg,  
New Delhi 110067

Sub: Issuance of NOC in r/o M/s office cum Shopping building & Multi Level Parking at Plot No 1069, LSC, Munirka, Olof Palme Road, New Delhi 110067.

Sir,

This has reference to your letter received through outdoor diary no 7015 dated 28/10/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 22.11.2022 in the presence of Mr. Ankur D Trivedi to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke management system not functional in the basement.
2. Sprinkler system could not be checked due to non availability of sprinkler testing value in the basement.
3. DG operated Fire fighting pump are not on auto mode.
4. The pressurisation of lift lobbies found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,



(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

9/11

Copy to:-

1. The Executive Engineer (Bldg) MCD, Green park Zone, Aurobindo Marg, New Delhi 110016