



C-16

75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/WZ/2022/ 682

Dated: 29/11/2022

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub: - Regarding issuance of FSC in r/o Epicuria Galley Pvt. Ltd., Plot No. 10, Ground Floor, Shivaji Place, Distt Centre, Raja Garden, New Delhi: - 110027.

Sir,

This is in reference to the online application received through MHA portal vide ID- Online ID 2022091617689 dated 16/09/2022, regarding issuance of Fire Safety Certificate in respect of aforesaid restaurant. In this connection, it is to inform you that the premises was inspected by officers concerned of this department on 17/11/2022 in the presence Sh. Ashok Yadav to check the fire safety arrangements provided in the building.

During the course of inspection, it was observed that the said eating house/restaurant is running at Ground floor of TDI Epicuria Mall (J.R. Sood & Company Pvt. Ltd.) in a building comprised of 02 Basement + Ground + 04 Upper Floor. FSC was issued by this department vide letter no. F6/DFS/MS/HQ/2020/95 dated 06/09/2020 (For Mall). A fire safety arrangement of the restaurant is interlinked with Mall's fire safety system. However, following shortcomings were observed: -

1. Sprinkler is required in left out area.
2. Detector system is required in left out area.
3. Exit Signage's are not provided.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Anil Garg)
Director
Delhi Fire Service

Copy to: -

1. The Owner/ Occupier M/s. Epicuria Galley Pvt. Ltd., Plot No. 10, Ground Floor, Shivaji Place, Distt Centre, Raja Garden, New Delhi: - 110027.
2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027.
Email Id :- dhowestzone@gmail.com

28/11/2022