

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001**

No. F6/DFS/MS/WZ/2022/ 3061

Dated: 06/12/2022

To,

The Owner/occupier,  
Galaxy Toyota (A unit of Galaxy Automobile Pvt. Ltd.),  
69/1, Moti Nagar, Najafgarh Road,  
Industrial Area, Moti Nagar,  
New Delhi-110015.

Subject: - Fire Safety certificate in respect of M/s Galaxy Toyota (A unit of Galaxy Automobile Pvt. Ltd.), 69/1, Moti Nagar, Najafgarh Road, Industrial Area, Moti Nagar, New Delhi-110015.

Sir,


In this connection, it is to inform you that the premises was inspected by the officers concerned of this department on 24/11/2022 in the presence of Sh. Krishna Rai (Purchasing) to check the Shortcomings already issued by this deptt. Vide Letter No. F6/DFS/MS/WZ/2022/1014 dated 09/05/2022.

During course of inspection, it was observed that the Galaxy Toyota is running at Basement, Ground plus One upper floor in a building comprised of Basement, Ground + One Upper floor. However, the status of shortcomings are as under.

S.N.	Shortcomings	Status
1.	Pumps are found non-functional.	Not Rectified
2.	Fire Check Door is found removed.	Not Rectified
3.	MOEFA found non-functional.	Not Rectified
4.	Internal Hydrant, Hose Reels, Sprinkler & Yard Hydrant are found non- functional.	Not Rectified

In view of the above shortcomings, Fire safety Certificate issued by his department cannot be revoked. You are requested to rectify the above shortcomings within 30 days from the date of issuance of this letter as per DFS Act 2007 & DFS Rules 2010 till such time use of occupancy at your own risk & responsibility.

Yours Faithfully

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy To: -

1. The Executive Engineer - I(Bldg.)HQ, NDMC, 9<sup>th</sup> Floor Civic Center Minto Road, New Delhi-110002.
2. The Dy. Director (Bldg), DDA, INA, Vikas sadan, New Delhi.