



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

C-56

No: F.6/DFS/MS/School/WZ/2022/ 734

Dated: 6/12/22

To

The Vice Principal,
Little Fairy Public School,
Ashok Vihar Ph- IV, New Delhi- 110052.

Sub.: Regarding renewal of Fire Safety Certificate in r/o Little Fairy Public School, Ashok Vihar Ph- IV, Delhi- 110052.

Sir,

This is in reference to your letter No. LFPS/AV/10/22/1297 dated 12.11.2022 on the subject cited above. In this connection, it is to inform you that the school building was inspected by the officer concerned of this department in your presence on 29.11.2022 to check the status of the fire safety arrangements already provided in the school building.

During the course of inspection, it was observed that the school is running at ground plus two upper floors in a building comprised of ground plus three upper floors. Fire safety arrangements such as fire extinguishers, first aid hose reel, down comer, terrace fire pump capacity 450 LPM, etc. found provided. However, following shortcomings were observed:

1. Terrace pumps are provided but not functional.
2. Hose reel hose found provided but not functional.
3. Overhead water tank capacity 5000 lts found provided against required 10,000 lts.
4. Exit signages found removed at some places.

In view of the above shortcomings, fire safety certificate cannot be renewed at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department.

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Directorate of Education, Old Secretariat, Delhi- 110054.

9c
2/12/22