

C-37

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F-6/DFS/MS/School/2022/737

Dated 08/12/2022

To

The Principal  
Rawalpindi Sanatan Dharma Sr. Sec. School  
Sabzi Mandi, Malka Ganj Road, Delhi-07


**Sub:** - Regarding issuance of fire safety certificate in r/o Rawalpindi Sanatan Dharma Sr. Sec. School located at Sabzi Mandi, Malka Ganj Road, Delhi-110007.

Sir,

Please refer to your letter received through email I.D dated 23.11.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 30.11.2022 to verify the fire safety measures issued vide Director of Education dated 17.01.2005 and observed that the school premise is comprised of ground & 02 upper floors. At the time of inspection Sh. B.R. Tamta (Teacher) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Fire extinguisher provided in the building were checked and found not functional.
2. First aid hose reel hose not provided.
3. Terrace level fire fighting pump capacity of 450lpm not provided.
4. Terrace level fire water tank capacity of 10,000ltrs not provided.
5. Exit signage not provided in the building.

Yours faithfully

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Ph:-011-23414250

Copy to: -

1. The Director of Education, Government of N.C.T of Delhi. Old Sectt. Delhi.