



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2022/733

Dated: 6/12/22

To

The Principal (Morning/Evening shift),
Sarvodaya Bal Vidyalaya,
Tughlakabad Extension, New Delhi- 110019;
School ID no. 1925056 & Building ID no. 19251137.

Sub:- Regarding issuance of Fire Safety Certificate in r/o **Sarvodaya Bal Vidyalaya located at Tughlakabad Extension, New Delhi- 110019**, School ID no. 1925056.

Sir,

With reference to your letter no. HOS/SBV/TE/2022/D/252 dated 10.11.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 14.11.2022 in the presence of Guard and it was observed that the school building is comprised of 05 blocks: A & B blocks - ground + 03 upper floors each & C, D, & E blocks – ground + 1 upper floor each. During the inspection following shortcomings were observed:-

1. First aid hose reels found non function.
2. Fire pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

7c Qh
25/11/22