

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F 6/DFS/MS/2022/ 71

Dated: 7/12/2022

cy8

To,

The Executive Engineer(E),
DTTDC Ltd, (A Government Undertaking),
Srinivaspuri, Lajpat Nagar,
Near Cambridge School,
Ring Road, New Delhi-110065

Sub: Regarding fire safety certificate in r/o world Class Skill Centre at Delhi Institute of Tool Engineering (Now DSEU, Wazirpur – I, Campus) located at Wazirpur Industrial Area, Delhi-110052.

Sir,

Please refer your No. 23(35)/DTTC/Engg./EE(E)/2022-23/395 dated 31.10.2022, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of construction of educational building (DITE,) at Wazirpur, New Delhi. Following shortcomings are observed:

1. FCD is not proposed in staircase as per the clause 7.11(j) of UBBL-2016.
2. Fire safety arrangements, such as overhead tank, terrace pump as per NBC (Part)-4 are not proposed.
3. The ladder for inspection of overhead tank is not proposed as per clause of 7.10.3 of UBBL 2016.
4. Staircase is not meeting the requirement of clause 8.4.3 (g) of UBBL-2016.
5. Floor area chart, door schedule is not proposed.
6. Exits are not arranged as per clause 7.5.10 of UBBL-2016.

Accordingly, the case is hereby rejected.

Yours faithfully,

(Atul Garg)
Director

011-23414000

W R