

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/2022/SZ/ 3096
To

Dated: 12/12/2022

Mr. R.P Singh (GM/Engg.)
Residential Blocks (No. 10, 11 & 12)-
Type II Quarters at Kidwai Nagar (East),
For GPRA, New Delhi- 110023

Sub: Regarding issuance of FSC in r/o Residential Blocks (No. 10, 11 & 12)-Type II Quarters at Kidwai Nagar (East), for GPRA, New Delhi- 110023

Sir,

This has reference to your letter no. NBCC/EKN-GPRA/TYPE-II/ED/DFS/2022/1533 Dated 06/10/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 19.11.2022 in the presence of Mr. Nitesh Kumar (DGM) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The sealing of shaft found removed.
2. First aid hose reel provided but non functional.
3. Fire fighting pumps provided are not on auto mode.
4. Exit Signage's found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

(ATUL GARG)
DIRECTOR

Copy to: -

1. The Executive Engineer, Building Department, NDMC, Palika Kendra, New Delhi 110002