



No. F6 /DFS/MS/Auditorium/SZ/2022 | 3116

Dated: 15/12/2022

To,  
The Executive Engineer (E).  
Central Public Works Department.  
Govt. of India, Safdarjung Hospital Electrical Division.  
New Delhi-110029.

**Sub:** - Regarding renewal of Fire Safety Certificate in r/o M/s Weightlifting Auditorium, JLN Sports Complex, Lodhi Road, New Delhi-110003.

Sir,

This has reference to the Outdoor diary no. 6746 dated 14.10.2022 on the subject cited above. it is informed that the said building was inspected by Assistant Divisional Officer (M. Road) from this department on 07.12.2022 in the presence of Mr. Sunil (AE) and Sri Shailendra (J.E) and it was observed that the building is comprised of Two Basements + Ground + 01 upper floor. During the inspection the following shortcomings were observed:

1. Fire check door (FCD) not working properly.
2. Ventilation system found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully  
  
(Atul Garg)  
Director  
Delhi Fire Service

**Copy to:-**

The Assistant Engineer (Electrical), M/s Weightlifting Auditorium, JLN Sports Complex, Lodhi Road, New Delhi-110003.