

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/Club/2022/ 3120

Dated 15/12/2022

To

Mr. Sanjeev Verma (Hony. Secretary)
M/s Anand Niketan Club
Anand Niketan, New Delhi 110021.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Anand Niketan Club at Anand Niketan New Delhi 110021.

Sir,

This has reference to your letter no. ANC/2924 dated 19/11/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 06.12.2022 in the presence of Mr. Satender Sharma to verify the fire safety measures installed in the building. During inspection, following points were observed:

- 1 First aid hose reel provided but non functional.
- 2 Sprinkler system provided but non functional.
- 3 Fire pumps are not on auto mode.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:

1. The Joint C P (Lic.) 1st Floor, P.S. Defence Colony, New Delhi 110049