



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


आजादी का
अमृत महोत्सव

CTT

No: F.6/DFS/MS/WZ/2022/ 75

Dated: 15/12/22

To

Prof. Nirmal Jindal,
Officiating Principal, Satyawati College,
Ashok Vihar, Phase- III, Delhi- 110052.

Sub.-: Regarding renewal of Fire Safety Certificate in r/o the Auditorium Building, Satyawati College, Ashok Vihar Phase- III, New Delhi- 52

Sir,


This is in reference to your e-mail dated 15.11.2022 vide ID-principal@satyawati.du.ac.in on the subject cited above. In this connection, it is to inform you that the auditorium building was inspected by the officers concerned of this department in the presence of Sh. Kamal Kumar, manager on 29.11.2022 to check the status of the fire safety arrangements already provided in the building.


During the course of inspection, it was observed that the building is comprised of ground & first floor only served by two staircases having width 1.5 mts each. Fire safety arrangements such as fire extinguishers, first aid hose reel, riser system, detection system, MOEFA, fire pump, etc. found provided. However, following shortcomings were observed:

1. Fire check door found removed.
2. Width of door is less than required width of 1.5 mts.
3. Foot lights of the auditorium found non-functional.
4. Longitudinal and side gangways shall be maintained as per Cinematograph Act.

In view of the above shortcomings, fire safety certificate cannot be renewed at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone


08/12/22