



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6 /DFS/MS/GH/SZ/2022/1009

Dated: 13/12/2022

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P.S Defence Colony, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Bamyam The Boutique Hotel (Guest House) located at 6-A, Ring Road, Lajpat Nagar-IV, New Delhi-24.

Sir,

This has reference to the online application I.D. no. 2022041907484 dated 03.11.2022 on the subject cited above, it is informed that the said guest house was inspected by Assistant Divisional Officer (M. Road) from this department on 02.12.2022 in the presence of Manager and it was observed that the building is comprised of Basement + Ground + 03 upper floors. During the inspection the following shortcomings were observed:

1. Fire check door not provided in the guest as required in the Gazette Notification dated 27.05.2019.
2. Hose reel found non functional.
3. CO detectors with panel and alarm not provided in the guest house as required in Gazette Notification dated 27.05.2019.
4. Fire pump found not functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Licensee, M/s Bamyam The Boutique Hotel (Guest House) located at 6-A, Ring Road, Lajpat Nagar-IV, New Delhi-24.

13/12/22