

C 26.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F.6/DFS/MS/111/NDZ/2022/ 703

Dated: 07/12/2022

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** - Regarding Online application ID No. 2022081616219 in r/o M/s Karim Hotel Pvt. Ltd.  
situated at 14/61, 17/11, 11/63, 4134, Gali Kababian, Jama Masjid, Delhi.

Sir,

This has a reference to online application ID No. 2022081616219 dated 17.08.2022 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officers concerned of this department on 03.11.2022 in presence of Mr. Aasif (Manager) to verify the fire safety measures installed in the building and observed that restaurant running at ground floor only. During inspection, following shortcomings were observed:

1. There are two exit having width of 1.50 mtr & 1.0 mtr against the required width of 1.50 mtr each respectively.
2. First aid hose reel not provided.
3. MOEFA not provided.
4. Internal hydrant 100 mm capacity not provided.
5. Overhead water tank capacity of 20,000 liters not provided.
6. Exit signage's not adequately provided.
7. Drawing provided is not matching with actual site, hence as built drawings to be uploaded on MHA portal.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service  
Tel: 0112341400

o/c  
07/12

**Copy to:-**

The Manager,

Karim Hotel Pvt. Ltd. at 14/61, 17/11, 11/63, 4134, Gali Kababian, Jama Masjid, Delhi.