

271

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2022/94/976

Dated:-25.11..2022

To

The Manager
Le-Roi Guest House,
2206, Raj Guru Road,
Chuna Mandi, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S **Le-Roi Guest House** located at 2206, Raj Guru Road, Chuna Mandi, Pahar Ganj, New Delhi. ID No. **2022092618218** dated **26/09/22**.

Sir,

This has reference to online id no. **2022092618218** dated **26/09/22**, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned of this department on 18/11/2022 in the presence of **Mr. Amit** and following shortcomings were observed:-

1. Fire Check doorson staircase and smoke management are not installed as per gazette notification dated 27.05.2019.
2. The building plan as uploaded on the portal does not match with existing profile of the guest house in r/o stilt floor & 4th floor. Fourth floor plan is also not submitted and a fresh undertaking is also required not to use any floor above third floor, as the stilt floor is being used other than parking.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.