

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

C-48

No. F6/DFS/MS/Bnqt./2022/SZ/ 236

Dated: 12/12/22

To,

The Dy. Health Officer,
Municipal Corporation of Delhi,
Public Health Department, West Zone,
Shivaji Enclave, Raja Garden, New Delhi.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s MHA Hospitality LLP Located at Plot No. A-143, Rewari Line Industrial Area, Mayapuri Phase-II, Delhi-110064.

Sir,

Please refer to letter Nil dated 26/10/2022 on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Mohit Allawadi was present and it was observed that the building is comprised of Basement, Stilt, ground plus two upper floors and have following shortcomings:-

1. Fire check doors not provided at some places.
2. Fire pumps are provided but not on auto mode.
3. Exit signage's are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service
9/12/22

Copy to:-

Sh. Mohit Allawadi, M/s MHA Hospitality LLP Located at Plot No. A-143, Rewari Line Industrial Area, Mayapuri Phase-II, Delhi-110064.