



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी का  
अमृत महोत्सव

C-37

No.F6/DFS/MS/School/SZ/2022/746

Dated: 13/12/2022

To

The Principal,  
Nanki Public School,  
C-1<sup>st</sup>, 407, Gali no. 9, Sangam Vihar,  
New Delhi-80.

**Sub:-** Regarding renewal of Fire Safety Certificate in respect of **Nanki Public School located at C-1<sup>st</sup>, 407, Gali no. 9, Sangam Vihar, New Delhi-80.**

Sir,

This has reference to your letter no. NPS/22-23/215 dated 20.09.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 25.11.2022 in the presence of Sh. Anand Kumar Jha (Manager) and it was observed that the school building is comprised of Ground + 3 upper floors. During the inspection following shortcomings was observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters.
2. 2 nos. of staircase having width of 1.50 mtrs each are not provided.
3. Hose reel found non functional.
4. Fire pump found non functional and had lower discharge and head.
5. Exit signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)

Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C. Defence Colony, New Delhi-24.

9/12/22