

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

C-131

No.F6/DFS/MS/GH/NDZ/ 2022/ 1012

Dated:-13/12/2022

To,

The Manager,
Hotel The Nest, (Delhi Intercontinental Hotels Pvt.Ltd)
11, Qutab Road, Ram Nagar,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hotel The Nest, 11, Qutab Road, Ram Nagar, New Delhi.


Sir,

This has reference to on line id no. 2022112220526 dated 22/11/22, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 05/12/2022 in the presence of **Manager** and following shortcomings were observed:

1. Fire Check doors & CO type detector are not provided as per Gazette Notification dated 27.05.2019.
2. Building plan as upload on the portal does not match with the existing profile of guest house.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the same for further consideration in the matter.

Yours faithfully,


12/12/22

(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to :-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.