

C-28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/School/2022/ 740

Dated: 12/12/2022

To

School In charge /HOS,
Govt. Girls Ser. Sec. School,
Pahar Ganj, New Delhi

Sub: Regarding issuance of FSC in r/o SPS type additional class room (ground + three upper floor) at Govt. Girls Ser. Sec. School located at Kesruwalan , Pahar Ganj, New Delhi

Sir,

This has reference to your mail id <aepwdsd4@gmail.com> dated 05.11.2022, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 01.12.2022 and observed that the 06 meter access road to the building for fire vehicle/tender is not available. Hence, fire safety certificate (FSC) cannot be issued to the said school.

Yours faithfully,


(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.