

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/School/NDZ/2022/ 739

Dated: 12.12.2022

To

Ms. Chand Bibi,(Principal),
Utkrisht Vidyalaya Turkman,
Road No.2,Maharaja Ranjeet Singh Marg,
New Delhi-02.


Sub: Application for renewal of fire safety certificate in respect of Utkrisht Vidyalaya Turkman Road No.2, Maharaja Ranjeet Singh, Marg, New Delhi-02.

Sir,

This has reference to your letter no. Nil dated 11.10.2022, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on dated 01.12.2022 in presence of **Ms.Chand Bibi (Principal)** and observed that the hose reel, over head tank and fire pump have been installed but found nonfunctional due to not connected with electric connection.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the complete compliance of the shortcomings for further consideration in the matter.

Yours faithfully,


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

✓