



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2022/ 744

Dated: 13/12/2022

To

The Principal,
White Roses Public School,
L-1st, 1657 Gali no. 30,
Sangam Vihar, New Delhi – 110080.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **White Roses Public School, L-1st, 1657 Gali no. 30, Sangam Vihar, New Delhi – 110080.**

Sir,

With reference to your letter no. nil dated nil on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 25.11.2022 in the presence of Manager and it was observed that the school building is comprised of Ground + 01 upper floor. During the inspection following shortcomings were observed:-

1. 6 meters road is not available for accessibility of fire engine..

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.