

C-29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 1011

Dated:-13/12/2022

To,

The Manager,
M/S Grand Shanti Palace Guest House,
18/1, Krishna Market, Main Bazar,
Pahar Ganj, New Delhi.

Sub: Regarding renewal of FSC in r/o M/S Grand Shanti Palace Guest House, 18/1, Krishna Market, Main Bazar, Pahar Ganj, New Delhi.


Sir,

This has reference to your online ID No. 2022083016853 dated 07/11/22, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 29.11.22 in presence of Sh. Hari Singh Rathore (Manager) and following shortcomings were observed:

1. Hose reel found nonfunctional.
2. In the application form establishment is situated at ground, 1st, 2nd & 3rd floor whereas guest rooms are shown at first floor only. Please clarify the upper floor occupancy.
3. Building Plan of all floors is required to be submitted with sanction/elevation.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,


12/12/22
(S. K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi