

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 1002

Dated:-12.11.2022

To,

The Manager,
M/S Amar Guest House,
1647-48, Opp. Krishna Market,
Pahar Ganj, New Delhi.

Sub: Regarding renewal of FSC in r/o M/S Amar Guest House at 1647-48, Opp. Krishna Market, Pahar Ganj, New Delhi.

Sir,

This has reference to your online id 2022102419373 dated 17/11/2022, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 29.11.22 in presence of **Sh. Salag Ram Rathore (Owner)** and following shortcomings were observed:

1. Fire check doors are not provided as per gazette notification 27.05.2019.
2. No. of rooms as shown in the building plan does not match with guest rooms as filled in application form.
3. Further, building Plan is not signed by architect & owner/occupier.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,


(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.